

# **2012 Edition of the Drinking Water Standards and Health Advisories**



---

# **2012 Edition of the Drinking Water Standards and Health Advisories**

**EPA 822-S-12-001**

**Office of Water  
U.S. Environmental Protection Agency  
Washington, DC**

**Spring 2012**  
Date of update: April, 2012

---

**Recycled/Recyclable**  
Printed on paper that contains  
at least 50% recycled fiber.



# ***Drinking Water Standards and Health Advisories***

Spring 2012

Page iii of vi

---

The Health Advisory (HA) Program, sponsored by the EPA's Office of Water (OW), publishes concentrations of drinking water contaminants at Drinking Water Specific Risk Level Concentration for cancer ( $10^{-4}$  Cancer Risk) and concentrations of drinking water contaminants at which noncancer adverse health effects are not anticipated to occur over specific exposure durations - One-day, Ten-day, and Lifetime - in the *Drinking Water Standards and Health Advisories* (DWSHA) tables. The One-day and Ten-day HAs are for a 10 kg child and the Lifetime HA is for a 70 kg adult. The daily drinking water consumption for the 10 kg child and 70 kg adult are assumed to be 1 L/day and 2 L/day, respectively. The Lifetime HA for the drinking water contaminant is calculated from its associated Drinking Water Equivalent Level (DWEL), obtained from its RfD, and incorporates a drinking water Relative Source Contribution (RSC) factor of contaminant-specific data or a default of 20% of total exposure from all sources. Maximum Contaminant Levels (MCLs) and Maximum Contaminant Level Goals (MCLGs) for some regulated drinking water contaminants are also published.

HAs serve as the informal technical guidance for unregulated drinking water contaminants to assist Federal, State and local officials, and managers of public or community water systems in protecting public health as needed. They are not to be construed as legally enforceable Federal standards. EPA's OW has provided MCL, MCLGs, RfDs, One-Day HAs, Ten-day HAs, DWELs, and Lifetime HAs. Drinking Water Specific Risk Level Concentration for cancer ( $10^{-4}$  Cancer Risk), and Cancer Descriptors in the DWSHA tables. HAs are intended to protect against noncancer effects. The  $10^{-4}$  Cancer Risk level provides information concerning cancer effects. The MCL values for specific drinking water contaminants must be used for regulated contaminants in public drinking water systems.

The DWSHA tables are revised periodically by the OW so that the benchmark values are consistent with the most current Agency assessments. Reference dose (RfD) values are updated to reflect the values in the Integrated Risk Information System (IRIS) and the Office of Pesticide Programs (OPP) Reregistration Eligibility Decisions (REDs) documents. The associated DWEL is recalculated accordingly.

A Lifetime noncancer benchmark is made available to risk assessment managers for comparison to the cancer risk level drinking water concentration ( $10^{-4}$  Cancer Risk) and to determine whether the noncancer Lifetime HA or the cancer risk level drinking water concentration provides a more meaningful scenario-specific risk reduction. In this regard, the Office of Water defines the Lifetime HA as the concentration in drinking water that is not expected to cause any adverse noncarcinogenic effects for a lifetime of exposure, whereas the  $10^{-4}$  Cancer Risk is the concentration of the chemical contaminant in drinking water that is associated with a specific probability of cancer. The Office of Water also advises consideration of the more conservative cancer risk levels ( $10^{-5}$ ,  $10^{-6}$ ), found in the IRIS or OPP RED source documents, if it is considered more appropriate for exposure-specific risk assessment.

# ***Drinking Water Standards and Health Advisories***

Spring 2012

Page iv of vi

---

Many of the values on the DWSHA tables have been revised since the original HAs were published. Revised RfDs,  $10^{-4}$  Cancer Risk values, and cancer designations or descriptors obtained from Integrated Risk Information System (IRIS), and One-day and Ten-day Health Advisories are presented in **BOLD** type. Revised RfDs,  $10^{-4}$  Cancer Risk values, and cancer designations or descriptors obtained from Office of Pesticide Program's Registration Eligibility Decision (OPP RED) are presented in ***BOLD ITALICS*** type.

The summaries of IRIS Toxicological Reviews from which the RfDs and cancer benchmarks, as well as the associated narratives and references can be accessed at: <http://www.epa.gov/IRIS>. Those from OPP REDs can be accessed at: <http://www.epa.gov/pesticides/reregistration/status.htm>.

In some cases, there is an HA value for a contaminant but there is no reference to an HA document. Such HA values can be found in the Drinking Water Criteria Document for the contaminant.

With a few exceptions, the RfDs, Health Advisories, and Cancer Risk values have been rounded to one significant figure following the convention adopted by IRIS.

For unregulated chemicals with current IRIS or OPP REDs RfDs, the Lifetime Health Advisories are calculated from the associated DWELs, using the RSC values published in the HA documents for the contaminants.

The DWSHA tables may be reached from the Water Science home page at: <http://www.epa.gov/waterscience/>. The DWSHA tables are accessed under the Drinking Water icon.

Copies the Tables may be ordered free of charge from

SAFE DRINKING WATER HOTLINE  
1-800-426-4791  
Monday thru Friday, 9:00 AM to 5:30 PM EST

# Drinking Water Standards and Health Advisories

Spring 2012

Page v of vi

---

## DEFINITIONS

The following definitions for terms used in the DWSHA tables are not all-encompassing, and should not be construed to be “official” definitions. They are intended to assist the user in understanding terms used in the DWSHA tables.

**Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. For example, it is the level of lead or copper which, if exceeded in over 10% of the homes tested, triggers treatment for corrosion control.

**Cancer Classification:** A descriptive weight-of-evidence judgment as to the likelihood that an agent is a human carcinogen and the conditions under which the carcinogenic effects may be expressed. Under the 2005 EPA *Guidelines for Carcinogen Risk Assessment*, Cancer Descriptors replace the earlier alpha numeric Cancer Group designations (US EPA 1986 guidelines). The Cancer Descriptors in the 2005 EPA *Guidelines for Carcinogen Risk Assessment* are as follows:

- “carcinogenic to humans” (**H**)
- “likely to be carcinogenic to humans” (**L**)
- “likely to be carcinogenic above a specified dose but not likely to be carcinogenic below that dose because a key event in tumor formation does not occur below that dose” (**L/N**)
- “suggestive evidence of carcinogenic potential” (**S**)
- “inadequate information to assess carcinogenic potential” (**I**)
- “not likely to be carcinogenic to humans” (**N**)

The letter abbreviations provided parenthetically above are now used in the DWSHA tables in place of the prior alpha numeric identifiers for chemicals that have been evaluated under the new guidelines (the 2005 guidelines or the 1996 and 1999 draft guidelines) or whose records in the DWSHA tables have been revised.

**Cancer Group:** A qualitative weight-of-evidence judgment as to the likelihood that a chemical may be a carcinogen for humans. Each chemical was placed into one of the following five categories (US EPA 1986 guidelines). The Cancer Group designations are given in the Tables for chemicals that have not yet been evaluated under the new guidelines or whose records in the DWSHA tables have been revised.

### Group Category

- A** Human carcinogen
- B** Probable human carcinogen:
  - B1** indicates limited human evidence

# ***Drinking Water Standards and Health Advisories***

Spring 2012

Page vi of vi

- 
- |          |  |
|----------|--|
|          | <b>B2</b> indicates sufficient evidence in animals and inadequate or no evidence in humans |
| <b>C</b> | Possible human carcinogen  |
| <b>D</b> | Not classifiable as to human carcinogenicity   |
| <b>E</b> | Evidence of noncarcinogenicity for humans  |

**10<sup>-4</sup> Cancer Risk:** The concentration of a chemical in drinking water corresponding to an excess estimated lifetime cancer risk of 1 in 10,000.

**Drinking Water Advisory:** A nonregulatory concentration of a contaminant in water that is likely to be without adverse effects on health and aesthetics for the period it is derived.

**DWEL:** Drinking Water Equivalent Level. A DWEL is a drinking water lifetime exposure level, assuming **100%** exposure from that medium, at which adverse, noncarcinogenic health effects would not be expected to occur.

**HA:** Health Advisory. An estimate of acceptable drinking water levels for a chemical substance based on health effects information; an HA is not a legally enforceable Federal standard, but serves as technical guidance to assist Federal, State, and local officials.

**One-Day HA:** The concentration of a chemical in drinking water that is not expected to cause any adverse noncarcinogenic effects for up to one day of exposure. The One-Day HA is intended to protect a 10-kg child consuming 1 liter of water per day.

**Ten-Day HA:** The concentration of a chemical in drinking water that is not expected to cause any adverse noncarcinogenic effects for up to ten days of exposure. The Ten-Day HA is also intended to protect a 10-kg child consuming 1 liter of water per day.

**Lifetime HA:** The concentration of a chemical in drinking water that is not expected to cause any adverse **noncarcinogenic effects** for a lifetime of exposure, incorporating a drinking water RSC factor of contaminant-specific data or a default of 20% of total exposure from all sources. The Lifetime HA is based on exposure of a 70-kg adult consuming 2 liters of water per day. For Lifetime HAs developed for drinking water contaminants before the Lifetime HA policy change to develop Lifetime HAs for all drinking water contaminants regardless of carcinogenicity status in this DWSHA update, the Lifetime HA for Group C carcinogens, as indicated by the 1986 Cancer Guidelines, includes an uncertainty adjustment factor of 10 for possible carcinogenicity.

**MCLG:** Maximum Contaminant Level Goal. A non-enforceable health benchmark goal which is set at a level at which no known or anticipated adverse effect on the health of persons is expected to occur and which allows an adequate margin of safety.

# ***Drinking Water Standards and Health Advisories***

Spring 2012

Page vii of vi

---

**MCL:** Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG as feasible using the best available analytical and treatment technologies and taking cost into consideration. MCLs are enforceable standards.

**Oral cancer slope factor:** The slope factor is the result of application of a low-dose extrapolation procedure and is presented as the risk per (mg/kg)/day.

**RfD:** Reference Dose. An estimate (with uncertainty spanning perhaps an order of magnitude) of a daily oral exposure to the human population (including sensitive subgroups) that is likely to be without an appreciable risk of deleterious effects during a lifetime.

**Risk Specific Level Concentration:** The concentration of the chemical contaminant in drinking water or air providing cancer risks of 1 in 10,000, 1 in 100,000, or 1 in 100,000,000.

**SDWR:** Secondary Drinking Water Regulations. Non-enforceable Federal guidelines regarding cosmetic effects (such as tooth or skin discoloration) or aesthetic effects (such as taste, odor, or color) of drinking water.

**TT:** Treatment Technique. A required process intended to reduce the level of a contaminant in drinking water.

**Unit Risk:** The unit risk is the quantitative estimate in terms of either risk per  $\mu\text{g/L}$  drinking water or risk per  $\mu\text{g/m}^3$  air breathed.

# ***Drinking Water Standards and Health Advisories***

Spring 2012

Page viii of vi

---

## **ABBREVIATIONS**


|              |  |
|--------------|--|
| <b>D</b>     | Draft  |
| <b>DWEL</b>  | Drinking Water Equivalent Level                |
| <b>DWSHA</b> | Drinking Water Standards and Health Advisories |
| <b>F</b>     | Final  |
| <b>HA</b>    | Health Advisory                                |
| <b>I</b>     | Interim  |
| <b>IRIS</b>  | Integrated Risk Information System             |
| <b>MCL</b>   | Maximum Contaminant Level                      |
| <b>MCLG</b>  | Maximum Contaminant Level Goal                 |
| <b>NA</b>    | Not Applicable                                 |
| <b>NOAEL</b> | No-Observed-Adverse-Effect Level               |
| <b>OPP</b>   | Office of Pesticide Programs                   |
| <b>OW</b>    | Office of Water                                |
| <b>P</b>     | Proposed                                       |
| <b>Pv</b>    | Provisional                                    |
| <b>RED</b>   | Registration Eligibility Decision              |
| <b>Reg</b>   | Regulation                                     |
| <b>RfD</b>   | Reference Dose                                 |
| <b>TT</b>    | Treatment Technique                            |



# Drinking Water Standards and Health Advisories

Spring 2012

Page 1 of 12

| Chemicals  | CASRN Number | Standards      |             |                 | Status HA Document | Health Advisories |                |                 |             |                  |                                      | Cancer Descriptor <sup>1</sup> |
|--|--------------|----------------|-------------|-----------------|--------------------|-------------------|----------------|-----------------|-------------|------------------|--------------------------------------|--------------------------------|
|  |              | Status Reg.    | MCLG (mg/L) | MCL (mg/L)      |                    | 10-kg Child       |                | RfD (mg/kg/day) | DWEL (mg/L) | Life-time (mg/L) | mg/L at 10 <sup>-4</sup> Cancer Risk |                                |
|  |              |                |             |                 |                    | One-day (mg/L)    | Ten-day (mg/L) |                 |             |                  |                                      |                                |
| ORGANICS   |              |                |             |                 |                    |                   |                |                 |             |                  |                                      |                                |
| Acenaphthene  | 83-32-9      | -              | -           | -               | -                  | -                 | -              | 0.06            | 2           | -                | -                                    | -                              |
| Acifluorfen (sodium)   | 62476-59-9   |                | -           | -               | F '88              | 2                 | 2              | 0.01            | 0.4         | -                | 0.1                                  | L/N                            |
| Acrylamide   | 79-06-1      | F              | zero        | TT <sup>2</sup> | F '87              | 1.5               | 0.3            | 0.002           | 0.07        | -                | -                                    | L                              |
| Acrylonitrile  | 107-13-1     |                | -           | -               | -                  | -                 | -              | -               | -           | -                | 0.006                                | B1                             |
| Alachlor   | 15972-60-8   | F              | zero        | 0.002           | F '88              | 0.1               | 0.1            | 0.01            | 0.4         | -                | 0.04                                 | B2                             |
| Aldicarb <sup>3</sup>  | 116-06-3     | F <sup>4</sup> | 0.001       | 0.003           | F '95              | 0.01              | 0.01           | 0.001           | 0.035       | 0.007            | -                                    | D                              |
| Aldicarb sulfone <sup>3</sup>  | 1646-88-4    | F <sup>4</sup> | 0.001       | 0.002           | F '95              | 0.01              | 0.01           | 0.001           | 0.035       | 0.007            | -                                    | D                              |
| Aldicarb sulfoxide <sup>3</sup>  | 1646-87-3    | F <sup>4</sup> | 0.001       | 0.004           | F '95              | 0.01              | 0.01           | 0.001           | 0.035       | 0.007            | -                                    | D                              |
| Aldrin   | 309-00-2     | -              | -           | -               | F '92              | 0.0003            | 0.0003         | 0.00003         | 0.001       | -                | 0.0002                               | B2                             |
| Ametryn  | 834-12-8     | -              | -           | -               | F '88              | 9                 | 9              | 0.009           | 0.3         | 0.06             | -                                    | D                              |
| Ammonium sulfamate   | 7773-06-0    | -              | -           | -               | F '88              | 20                | 20             | 0.2             | 8           | 2                | -                                    | D                              |
| Anthracene (PAH) <sup>5</sup>  | 120-12-7     | -              | -           | -               | -                  | -                 | -              | 0.3             | 10          | -                | -                                    | D                              |
| Atrazine   | 1912-24-9    | F              | 0.003       | 0.003           | F '88              | -                 | -              | 0.02            | 0.7         | -                | -                                    | N                              |
| Baygon   | 114-26-1     | -              | -           | -               | F '88              | 0.04              | 0.04           | 0.004           | 0.1         | 0.003            | -                                    | C                              |
| Bentazon   | 25057-89-0   | -              | -           | -               | F '99              | 0.3               | 0.3            | 0.03            | 1           | 0.2              | -                                    | E                              |
| Benz[a]anthracene (PAH)  | 56-55-3      | -              | -           | -               | -                  | -                 | -              | -               | -           | -                | -                                    | B2                             |
| Benzene  | 71-43-2      | F              | zero        | 0.005           | F '87              | 0.2               | 0.2            | 0.004           | 0.1         | 0.003            | 1 to 10                              | H                              |
| Benzo[a]pyrene (PAH)   | 50-32-8      | F              | zero        | 0.0002          | -                  | -                 | -              | -               | -           | -                | 0.0005                               | B2                             |
| Benzo[b]fluoranthene (PAH)   | 205-99-2     | -              | -           | -               | -                  | -                 | -              | -               | -           | -                | -                                    | B2                             |
| Benzo[g,h,i]perylene (PAH)   | 191-24-2     | -              | -           | -               | -                  | -                 | -              | -               | -           | -                | -                                    | D                              |
| Benzo[k]fluoranthene (PAH)   | 207-08-9     | -              | -           | -               | -                  | -                 | -              | -               | -           | -                | -                                    | B2                             |
| Bis(2-chloro-1-methylethyl) ether  | 108-60-1     | -              | -           | -               | F '89              | 4                 | 4              | 0.04            | 1           | 0.3              | -                                    | -                              |
| Bromacil   | 314-40-9     | -              | -           | -               | F '88              | 5                 | 5              | 0.1             | 3.5         | 0.07             | -                                    | C                              |
| Bromobenzene   | 108-86-1     | -              | -           | -               | D '86              | 4                 | 4              | 0.008           | 0.3         | 0.06             | -                                    | I                              |

<sup>1</sup> Chemicals evaluated under the 2005 Cancer Guidelines or the 1996 or 1999 drafts are demoted by an abbreviation for their weight-of-the-evidence descriptor (see page iii). If the agency has not completed a new assessment for the chemical, the 1986 Guidelines Group designation (see page iii) is given in the Cancer Descriptor column.

<sup>2</sup> When Acrylamide is used in drinking water systems, the combination (or product) of dose and monomer level shall not exceed that equivalent to a polyacrylamide polymer containing 0.05% monomer dosed at 1 mg/L.

<sup>3</sup> The MCL value for any combination of two or more of these three chemicals should not exceed 0.007 mg/L because of a similar mode of action.

<sup>4</sup> Administrative stay of the effective date.

<sup>5</sup> PAH = Polycyclic aromatic hydrocarbon.

# Drinking Water Standards and Health Advisories

Spring 2012

Page 2 of 11

| Chemicals                  | CASRN Number | Standards   |             |                   | Status HA Document | Health Advisories |                |                 |             |                  |                                      | Cancer Descriptor |
|----------------------------|--------------|-------------|-------------|-------------------|--------------------|-------------------|----------------|-----------------|-------------|------------------|--------------------------------------|-------------------|
|                            |              | Status Reg. | MCLG (mg/L) | MCL (mg/L)        |                    | 10-kg Child       |                | RfD (mg/kg/day) | DWEL (mg/L) | Life-time (mg/L) | mg/L at 10 <sup>-4</sup> Cancer Risk |                   |
|                            |              |             |             |                   |                    | One-day (mg/L)    | Ten-day (mg/L) |                 |             |                  |                                      |                   |
| Bromochloromethane         | 74-97-5      | -           | -           | -                 | F '89              | 50                | 1              | 0.01            | 0.5         | 0.09             | -                                    | D                 |
| Bromodichloromethane (THM) | 75-27-4      | F           | zero        | 0.08 <sup>1</sup> | -                  | 1                 | 0.6            | 0.003           | 0.1         | -                | 0.1                                  | L                 |
| Bromoform (THM)            | 75-25-2      | F           | zero        | 0.08 <sup>1</sup> | -                  | 5                 | 0.2            | 0.03            | 1           | -                | 0.8                                  | L                 |
| Bromomethane               | 74-83-9      | -           | -           | -                 | D '89              | 0.1               | 0.1            | 0.001           | 0.05        | 0.01             | -                                    | D                 |
| Butyl benzyl phthalate     | 85-68-7      | -           | -           | -                 | -                  | -                 | -              | 0.2             | 7           | -                | -                                    | C                 |
| Butylate                   | 2008-41-5    | -           | -           | -                 | F '89              | 2                 | 2              | 0.05            | 2           | 0.4              | -                                    | D                 |
| Carbaryl                   | 63-25-2      | -           | -           | -                 | F '88              | 1                 | 1              | <b>0.01</b>     | 0.4         | -                | 4                                    | <b>L</b>          |
| Carbofuran                 | 1563-66-2    | F           | 0.04        | 0.04              | F '87              | -                 | -              | <b>0.00006</b>  | -           | -                | -                                    | <b>N</b>          |
| Carbon tetrachloride       | 56-23-5      | F           | zero        | 0.005             | F '87              | 4                 | 0.2            | <b>0.004</b>    | 0.1         | <b>0.03</b>      | <b>0.05</b>                          | <b>L</b>          |
| Carboxin                   | 5234-68-4    | -           | -           | -                 | F '88              | 1                 | 1              | 0.1             | 3.5         | 0.7              | -                                    | D                 |
| Chloramben                 | 133-90-4     | -           | -           | -                 | F '88              | 3                 | 3              | 0.015           | 0.5         | 0.1              | -                                    | D                 |
| Chlordane                  | 12798-03-6   | F           | zero        | 0.002             | F '87              | 0.06              | 0.06           | <b>0.0005</b>   | 0.02        | <b>0.004</b>     | <b>0.01</b>                          | B2                |
| Chloroform (THM)           | 67-66-3      | F           | 0.07        | 0.08 <sup>1</sup> | -                  | 4                 | 4              | <b>0.01</b>     | 0.35        | 0.07             | -                                    | <b>L/N</b>        |
| Chloromethane              | 74-87-3      | -           | -           | -                 | F '89              | 9                 | 0.4            | -               | -           | -                | -                                    | <b>I</b>          |
| Chlorophenol (2-)          | 95-57-8      | -           | -           | -                 | D '94              | 0.5               | 0.5            | 0.005           | 0.2         | 0.04             | -                                    | D                 |
| Chlorothalonil             | 1897-45-6    | -           | -           | -                 | F '88              | 0.2               | 0.2            | 0.015           | 0.5         | -                | 0.15                                 | B2                |
| Chlorotoluene o-           | 95-49-8      | -           | -           | -                 | F '89              | 2                 | 2              | 0.02            | 0.7         | 0.1              | -                                    | D                 |
| Chlorotoluene p-           | 106-43-4     | -           | -           | -                 | F '89              | 2                 | 2              | 0.02            | 0.7         | 0.1              | -                                    | D                 |
| Chlorpyrifos               | 2921-88-2    | -           | -           | -                 | F '92              | 0.03              | 0.03           | <b>0.0003</b>   | 0.01        | 0.002            | -                                    | <b>D</b>          |
| Chrysene (PAH)             | 218-01-9     | -           | -           | -                 | -                  | -                 | -              | -               | -           | -                | -                                    | B2                |
| Cyanazine                  | 21725-46-2   | -           | -           | -                 | D '96              | 0.1               | 0.1            | 0.002           | 0.07        | 0.001            | -                                    |                   |

<sup>1</sup> 1998 Final Rule for Disinfectants and Disinfection By-products: The total for trihalomethanes (THM) is 0.08 mg/L.

# Drinking Water Standards and Health Advisories

Spring 2012

Page 3 of 12

| Chemicals                              | CASRN Number | Standards   |             |                   | Status HA Document | Health Advisories |                |                 |             |                  |                                      | Cancer Descriptor |
|--|--------------|-------------|-------------|-------------------|--------------------|-------------------|----------------|-----------------|-------------|------------------|--------------------------------------|-------------------|
|  |              | Status Reg. | MCLG (mg/L) | MCL (mg/L)        |                    | 10-kg Child       |                | RfD (mg/kg/day) | DWEL (mg/L) | Life-time (mg/L) | mg/L at 10 <sup>-4</sup> Cancer Risk |                   |
|  |              |             |             |                   |                    | One-day (mg/L)    | Ten-day (mg/L) |                 |             |                  |                                      |                   |
| Cyanogen chloride <sup>1</sup>         | 506-77-4     | -           | -           | -                 | -                  | 0.05              | 0.05           | 0.05            | 2           | -                | -                                    | D                 |
| 2,4-D (2,4-dichlorophenoxyacetic acid) | 94-75-7      | F           | 0.07        | 0.07              | F '87              | 1                 | 0.3            | <b>0.005</b>    | 0.2         | -                | -                                    | <b>D</b>          |
| DCPA (Dacthal)                         | 1861-32-1    | -           | -           | -                 | F '08              | 2                 | 2              | <b>0.01</b>     | 0.35        | 0.07             | -                                    | <b>C</b>          |
| Dalapon (sodium salt)                  | 75-99-0      | F           | 0.2         | 0.2               | F '89              | 3                 | 3              | 0.03            | 0.9         | 0.2              | -                                    | D                 |
| Di(2-ethylhexyl)adipate                | 103-23-1     | F           | 0.4         | 0.4               | -                  | 20                | 20             | 0.6             | 20          | 0.4              | 3                                    | C                 |
| Di(2-ethylhexyl)phthalate              | 117-81-7     | F           | zero        | 0.006             | -                  | -                 | -              | 0.02            | 0.7         | -                | 0.3                                  | B2                |
| Diazinon                               | 333-41-5     | -           | -           | -                 | F '88              | 0.02              | 0.02           | <b>0.0002</b>   | 0.007       | 0.001            | -                                    | <b>E</b>          |
| Dibromochloromethane (THM)             | 124-48-1     | F           | 0.06        | 0.08 <sup>2</sup> | -                  | 0.6               | 0.6            | 0.02            | 0.7         | 0.06             | 0.08                                 | S                 |
| Dibromochloropropane (DBCP)            | 96-12-8      | F           | zero        | 0.0002            | F '87              | 0.2               | 0.05           | -               | -           | -                | 0.003                                | B2                |
| Dibutyl phthalate                      | 84-74-2      | -           | -           | -                 | -                  | -                 | -              | <b>0.1</b>      | 4           | -                | -                                    | D                 |
| Dicamba                                | 1918-00-9    | -           | -           | -                 | F '88              | -                 | -              | <b>0.5</b>      | 18          | 4                | -                                    | N                 |
| Dichloroacetic acid                    | 76-43-6      | F           | zero        | 0.06 <sup>3</sup> | -                  | <b>3</b>          | <b>3</b>       | <b>0.004</b>    | 0.1         | <b>0.03</b>      | <b>0.07</b>                          | <b>L</b>          |
| Dichlorobenzene o-                     | 95-50-1      | F           | 0.6         | 0.6               | F '87              | 9                 | 9              | 0.09            | 3           | 0.6              | -                                    | D                 |
| Dichlorobenzene — <sup>4</sup>         | 541-73-1     | -           | -           | -                 | F '87              | 9                 | 9              | 0.09            | 3           | 0.6              | -                                    | D                 |
| Dichlorobenzene p-                     | 106-46-7     | F           | 0.075       | 0.075             | F '87              | 11                | 11             | 0.1             | 4           | 0.075            | -                                    | C                 |
| Dichlorodifluoromethane                | 75-71-8      | -           | -           | -                 | F '89              | 40                | 40             | 0.2             | 5           | 1                | -                                    | D                 |
| Dichloroethane (1,2-)                  | 107-06-2     | F           | zero        | 0.005             | F '87              | 0.7               | 0.7            | -               | -           | -                | 0.04                                 | B2                |
| Dichloroethylene (1,1-)                | 75-35-4      | F           | 0.007       | 0.007             | F '87              | 2                 | 1              | <b>0.05</b>     | 2           | <b>0.4</b>       | <b>0.006</b>                         | <b>S</b>          |
| Dichloroethylene (cis-1,2-)            | 156-59-2     | F           | 0.07        | 0.07              | F '90              | 4                 | <b>3</b>       | <b>0.002</b>    | 0.07        | <b>0.01</b>      | -                                    | <b>I</b>          |
| Dichloroethylene (trans-1,2-)          | 156-60-5     | F           | 0.1         | 0.1               | F '87              | 20                | <b>2</b>       | <b>0.02</b>     | 0.7         | 0.1              | -                                    | <b>I</b>          |
| Dichloromethane                        | 75-09-2      | F           | zero        | 0.005             | D '93              | 10                | 2              | 0.06            | 2           | <b>0.2</b>       | 0.5                                  | <b>L</b>          |
| Dichlorophenol (2,4-)                  | 120-83-2     | -           | -           | -                 | D '94              | 0.03              | 0.03           | 0.003           | 0.1         | 0.02             | -                                    | E                 |
| Dichloropropane (1,2-)                 | 78-87-5      | F           | zero        | 0.005             | F '87              | -                 | 0.09           | -               | -           | -                | 0.06                                 | B2                |
| Dichloropropene (1,3-)                 | 542-75-6     | -           | -           | -                 | F '88              | 0.03              | 0.03           | <b>0.03</b>     | 1           | -                | <b>0.04</b>                          | <b>L</b>          |
| Dieldrin                               | 60-57-1      | -           | -           | -                 | F '88              | 0.0005            | 0.0005         | 0.00005         | 0.002       | -                | 0.0002                               | B2                |
| Diethyl phthalate                      | 84-66-2      | -           | -           | -                 | -                  | -                 | -              | 0.8             | 30          | -                | -                                    | D                 |

<sup>1</sup> Under review.

<sup>2</sup> 1998 Final Rule for Disinfectants and Disinfection By-products: The total for trihalomethanes is 0.08 mg/L.

<sup>3</sup> 1998 Final Rule for Disinfectants and Disinfection By-products: The total for five haloacetic acids is 0.06 mg/L.

<sup>4</sup> The values for m-dichlorobenzene are based on data for o-dichlorobenzene.

# Drinking Water Standards and Health Advisories

Spring 2012

Page 4 of 12

| Chemicals                               | CASRN Number | Standards   |             |                 | Status HA Document | Health Advisories |                |                 |             |                  |                                      | Cancer Descriptor |
|---|--------------|-------------|-------------|-----------------|--------------------|-------------------|----------------|-----------------|-------------|------------------|--------------------------------------|-------------------|
|   |              | Status Reg. | MCLG (mg/L) | MCL (mg/L)      |                    | 10-kg Child       |                | RfD (mg/kg/day) | DWEL (mg/L) | Life-time (mg/L) | mg/L at 10 <sup>-4</sup> Cancer Risk |                   |
|   |              |             |             |                 |                    | One-day (mg/L)    | Ten-day (mg/L) |                 |             |                  |                                      |                   |
| Diisopropylmethylphosphonate            | 1445-75-6    | -           | -           | -               | F '89              | 8                 | 8              | 0.08            | 3           | 0.6              | -                                    | D                 |
| Dimethrin                               | 70-38-2      | -           | -           | -               | F '88              | 10                | 10             | 0.3             | 10          | 2                | -                                    | D                 |
| Dimethyl methylphosphonate              | 756-79-6     | -           | -           | -               | F '92              | 2                 | 2              | 0.2             | 7           | 0.1              | 0.7                                  | C                 |
| Dimethyl phthalate                      | 131-11-3     | -           | -           | -               | -                  | -                 | -              | -               | -           | -                | -                                    | D                 |
| Dinitrobenzene (1,3-)                   | 99-65-0      | -           | -           | -               | F '91              | 0.04              | 0.04           | 0.0001          | 0.005       | 0.001            | -                                    | D                 |
| Dinitrotoluene (2,4-)                   | 121-14-2     | -           | -           | -               | F '08              | 1                 | 1              | 0.002           | 0.1         | -                | 0.005                                | L                 |
| Dinitrotoluene (2,6-)                   | 606-20-2     | -           | -           | -               | F '08              | 0.4               | 0.04           | 0.001           | 0.04        | -                | 0.005                                | L                 |
| Dinitrotoluene (2,6 & 2,4) <sup>1</sup> |              | -           | -           | -               | F '92              | -                 | -              | -               | -           | -                | 0.005                                | B2                |
| Dinoseb                                 | 88-85-7      | F           | 0.007       | 0.007           | F '88              | 0.3               | 0.3            | 0.001           | 0.035       | 0.007            | -                                    | D                 |
| Dioxane p-                              | 123-91-1     | -           | -           | -               | F '87              | 4                 | 0.4            | <b>0.03</b>     | 1           | 0.2              | <b>.035</b>                          | <b>L</b>          |
| Diphenamid                              | 957-51-7     | -           | -           | -               | F '88              | 0.3               | 0.3            | 0.03            | 1           | 0.2              | -                                    | D                 |
| Diquat                                  | 85-00-7      | F           | 0.02        | 0.02            | -                  | -                 | -              | <b>0.005</b>    | 0.02        | -                | -                                    | <b>E</b>          |
| Disulfoton                              | 298-04-4     | -           | -           | -               | F '88              | 0.01              | 0.01           | <b>0.0001</b>   | 0.0035      | 0.0007           | -                                    | <b>E</b>          |
| Dithiane (1,4-)                         | 505-29-3     | -           | -           | -               | F '92              | 0.4               | 0.4            | 0.01            | 0.4         | 0.08             | -                                    | D                 |
| Diuron                                  | 330-54-1     | -           | -           | -               | F '88              | 1                 | 1              | <b>0.003</b>    | 0.1         | -                | <b>0.2</b>                           | <b>L</b>          |
| Endothall                               | 145-73-3     | F           | 0.1         | 0.1             | F '88              | 0.8               | 0.8            | <b>0.007</b>    | 0.25        | 0.05             | -                                    | <b>N</b>          |
| Endrin                                  | 72-20-8      | F           | 0.002       | 0.002           | F '87              | 0.02              | 0.005          | <b>0.0003</b>   | 0.01        | 0.002            | -                                    | I                 |
| Epichlorohydrin                         | 106-89-8     | F           | zero        | TT <sup>2</sup> | F '87              | 0.1               | 0.1            | 0.002           | 0.07        | -                | <b>0.3</b>                           | B2                |
| Ethylbenzene                            | 100-41-4     | F           | 0.7         | 0.7             | F '87              | 30                | 3              | 0.1             | 3           | 0.7              | -                                    | D                 |
| Ethylene dibromide (EDB) <sup>3</sup>   | 106-93-4     | F           | zero        | 0.00005         | F '87              | 0.008             | 0.008          | <b>0.009</b>    | 0.3         | -                | <b>0.002</b>                         | <b>L</b>          |
| Ethylene glycol                         | 107-21-1     | -           | -           | -               | F '87              | 20                | 6              | <b>2</b>        | 70          | 14               | -                                    | D                 |
| Ethylene Thiourea (ETU)                 | 96-45-7      | -           | -           | -               | F '88              | 0.3               | 0.3            | <b>0.0002</b>   | 0.007       | -                | <b>0.06</b>                          | B2                |
| Fenamiphos                              | 22224-92-6   | -           | -           | -               | F '88              | 0.009             | 0.009          | <b>0.0001</b>   | 0.0035      | 0.0007           | -                                    | <b>E</b>          |

<sup>1</sup> Technical grade.








<sup>2</sup> When epichlorohydrin is used in drinking water systems, the combination (or product) of dose and monomer level shall not exceed that equivalent to an epichlorohydrin-based polymer containing 0.01% monomer dosed at 20 mg/L.

<sup>3</sup> 1,2-dibromoethane.

# Drinking Water Standards and Health Advisories

Spring 2012

Page 5 of 12

| Chemicals   | CAS Number | Standards      |                |               | Status<br>HA<br>Standards | Health Advisories |                   |                    |                |                     |  | Cancer<br>Descriptor |
|---|------------|----------------|----------------|---------------|---------------------------|-------------------|-------------------|--------------------|----------------|---------------------|--|----------------------|
|   |            | Status<br>Reg. | MCLG<br>(mg/L) | MCL<br>(mg/L) |                           | 10-kg Child       |                   | RfD<br>(mg/kg/day) | DWEL<br>(mg/L) | Life-time<br>(mg/L) | mg/L at<br>10 <sup>-4</sup> Cancer<br>Risk |                      |
|   |            |                |                |               |                           | One-day<br>(mg/L) | Ten-day<br>(mg/L) |                    |                |                     |  |                      |
| Fluometuron            | 2164-17-2  | -              | -              | -             | F '88                     | 2                 | 2                 | 0.01               | 0.5            | 0.09                | -  | D                    |
| Fluorene (PAH)  | 86-73-7    | -              | -              | -             | -                         | -                 | -                 | 0.04               | 1              | -                   | -  | D                    |
| Fonofos   | 944-22-9   | -              | -              | -             | F '88                     | 0.02              | 0.02              | 0.002              | 0.07           | 0.01                | -  | D                    |
| Formaldehyde           | 50-00-0    | -              | -              | -             | D '93                     | 10                | 5                 | <b>0.2</b>         | 7              | 1                   | -  | B1 <sup>1</sup>      |
| Glyphosate             | 1071-83-6  | F              | 0.7            | 0.7           | F '88                     | 20                | 20                | <b>2</b>           | 70             | -                   | -  | D                    |
| Heptachlor             | 76-44-8    | F              | zero           | 0.0004        | F '87                     | 0.01              | 0.01              | 0.0005             | 0.02           | -                   | 0.0008                                     | B2                   |
| Heptachlor epoxide     | 1024-57-3  | F              | zero           | 0.0002        | F '87                     | 0.01              | -                 | 0.00001            | 0.0004         | -                   | 0.0004                                     | B2                   |
| Hexachlorobenzene   | 118-74-1   | F              | zero           | 0.001         | F '87                     | 0.05              | 0.05              | 0.0008             | 0.03           | -                   | 0.002                                      | B2                   |
| Hexachlorobutadiene <sup>2</sup>  | 87-68-3    | -              | -              | -             | -                         | 0.3               | 0.3               | 0.0003             | 0.01           | -                   | 0.09                                       | L                    |
| Hexachlorocyclopentadiene   | 77-47-4    | F              | 0.05           | 0.05          | -                         | -                 | -                 | <b>0.006</b>       | 0.2            | -                   | -  | N                    |
| Hexachloroethane  | 67-72-1    | -              | -              | -             | F '91                     | 5                 | 5                 | 0.001              | 0.04           | 0.001               | <b>0.3</b>                                 | C                    |
| Hexane (n-)   | 110-54-3   | -              | -              | -             | F '87                     | 10                | 4                 | -                  | -              | -                   | -  | I                    |
| Hexazinone  | 51235-04-2 | -              | -              | -             | F '96                     | 3                 | 2                 | <b>0.05</b>        | 2              | 0.4                 | -  | D                    |
| HMX <sup>3</sup>  | 2691-41-0  | -              | -              | -             | F '88                     | 5                 | 5                 | 0.05               | 2              | 0.4                 | -  | D                    |
| Indeno[1,2,3,-c,d]pyrene (PAH)  | 193-39-5   | -              | -              | -             | -                         | -                 | -                 | -                  | -              | -                   | -  | B2                   |
| Isophorone  | 78-59-1    | -              | -              | -             | F '92                     | 15                | 15                | 0.2                | 7              | 0.1                 | 4  | C                    |
| Isopropyl methylphosphonate   | 1832-54-8  | -              | -              | -             | F '92                     | 30                | 30                | 0.1                | 3.5            | 0.7                 | -  | D                    |
| Isopropyl  ne (cumene) | 98-82-8    | -              | -              | -             | D '87                     | 11                | 11                | 0.1                | 4              | -                   | -  | D                    |
| Lindane <sup>4</sup>   | 58-89-9    | F              | 0.0002         | 0.0002        | F '87                     | 1                 | 1                 | <b>0.005</b>       | 0.2            | -                   | -  | S                    |
| Malathion   | 121-75-5   | -              | -              | -             | F '92                     | 0.2               | 0.2               | <b>0.07</b>        | 2              | 0.5                 | -  | S                    |
| Maleic hydrazide  | 123-33-1   | -              | -              | -             | F '88                     | 10                | 10                | 0.5                | 20             | 4                   | -  | D                    |
| MCPA <sup>5</sup>   | 94-74-6    | -              | -              | -             | F '88                     | 0.1               | 0.1               | <b>0.004</b>       | 0.14           | 0.03                | -  | N                    |
| Methomyl  | 16752-77-5 | -              | -              | -             | F '88                     | 0.3               | 0.3               | 0.025              | 0.9            | 0.2                 | -  | E                    |
| Methoxychlor  | 72-43-5    | F              | 0.04           | 0.04          | F '87                     | 0.05              | 0.05              | <b>0.005</b>       | 0.2            | 0.04                | -  | D                    |
| Methyl ethyl ketone   | 78-93-3    | -              | -              | -             | F '87                     | 75                | 7.5               | <b>0.6</b>         | 20             | 4                   | -  | D                    |
| Methyl parathion  | 298-00-0   | -              | -              | -             | F '88                     | 0.3               | 0.3               | <b>0.0002</b>      | 0.007          | 0.001               | -  | N                    |

<sup>1</sup> Carcinogenicity based on inhalation exposure.

<sup>2</sup> Regulatory Determination Health Effects Support Document for Hexachlorobutadiene ([http://www.epa.gov/safewater/ccl/pdfs/reg\\_determine1/support\\_cc1\\_hexachlorobutadiene\\_healtheffects.pdf](http://www.epa.gov/safewater/ccl/pdfs/reg_determine1/support_cc1_hexachlorobutadiene_healtheffects.pdf)).

<sup>3</sup> HMX = octahydro-1,3,5,7-tetranitro-1,3,5,7-tetrazocine.

<sup>4</sup> Lindane =  $\gamma$  - hexachlorocyclohexane.

<sup>5</sup> MCPA = 4 (chloro-2-methoxyphenoxy) acetic acid.

# Drinking Water Standards and Health Advisories

Spring 2012

Page 6 of 12

| Chemicals                              | CASRN Number | Standards   |             |                   | Status HA Document | Health Advisories |                |                 |             |                  |                                      | Cancer Descriptor    |
|--|--------------|-------------|-------------|-------------------|--------------------|-------------------|----------------|-----------------|-------------|------------------|--------------------------------------|----------------------|
|  |              | Status Reg. | MCLG (mg/L) | MCL (mg/L)        |                    | 10-kg Child       |                | RfD (mg/kg/day) | DWEL (mg/L) | Life-time (mg/L) | mg/L at 10 <sup>-4</sup> Cancer Risk |                      |
|  |              |             |             |                   |                    | One-day (mg/L)    | Ten-day (mg/L) |                 |             |                  |                                      |                      |
| Metolachlor                            | 51218-45-2   | -           | -           | -                 | F '88              | 2                 | 2              | <i>0.1</i>      | 3.5         | 0.7              | -                                    | <i>C</i>             |
| Metribuzin                             | 21087-64-9   | -           | -           | -                 | F '88              | 5                 | 5              | <i>0.01</i>     | 0.35        | 0.07             | -                                    | <i>D</i>             |
| Monochloroacetic acid                  | 79-11-8      | F           | 0.03        | 0.06 <sup>1</sup> | -                  | 0.2               | 0.2            | 0.01            | 0.35        | 0.07             | -                                    | I                    |
| Monochlorobenzene                      | 108-90-7     | F           | 0.1         | 0.1               | F '87              | 4                 | 4              | <b>0.02</b>     | 0.7         | 0.1              | -                                    | D                    |
| Naphthalene                            | 91-20-3      | -           | -           | -                 | F '90              | 0.5               | 0.5            | <b>0.02</b>     | 0.7         | 0.1              | -                                    | I                    |
| Nitrocellulose <sup>2</sup>            | 9004-70-0    | -           | -           | -                 | F '88              | -                 | -              | -               | -           | -                | -                                    | -                    |
| Nitroguanidine                         | 556-88-7     | -           | -           | -                 | F '90              | 10                | 10             | 0.1             | 3.5         | 0.7              | -                                    | D                    |
| Nitrophenol p-                         | 100-02-7     | -           | -           | -                 | F '92              | 0.8               | 0.8            | 0.008           | 0.3         | 0.06             | -                                    | D                    |
| N-nitrosodimethylamine                 |              | -           | -           | -                 | -                  | -                 | -              | -               | -           | -                | <b>0.00007</b>                       | <b>B<sub>2</sub></b> |
| Oxamyl (Vydate)                        | 23135-22-0   | F           | 0.2         | 0.2               | F '05              | 0.01              | 0.01           | 0.001           | 0.035       |                  | -                                    | N                    |
| Paraquat                               | 1910-42-5    | -           | -           | -                 | F '88              | 0.1               | 0.1            | <i>0.0045</i>   | 0.2         | 0.03             | -                                    | <i>E</i>             |
| Pentachlorophenol                      | 87-86-5      | F           | zero        | 0.001             | F '87              | 1                 | 0.3            | <b>0.005</b>    | 0.2         | 0.04             | <b>0.009</b>                         | <b>L</b>             |
| PFOA <sup>3</sup>                      | 335-67-1     | -           | -           | -                 | Pv '09             | -                 | -              | -               | -           | -                | -                                    | -                    |
| PFOS <sup>4</sup>                      | 1763-23-1    | -           | -           | -                 | Pv '09             | -                 | -              | -               | -           | -                | -                                    | -                    |
| Phenanthrene (PAH)                     | 85-01-8      | -           | -           | -                 | -                  | -                 | -              | -               | -           | -                | -                                    | D                    |
| Phenol                                 | 108-95-2     | -           | -           | -                 | D '92              | 6                 | 6              | <b>0.3</b>      | 11          | 2                | -                                    | D                    |
| Picloram                               | 1918-02-1    | F           | 0.5         | 0.5               | F '88              | 20                | 20             | <i>0.02</i>     | 0.7         | -                | -                                    | D                    |
| Polychlorinated biphenyls (PCBs)       | 1336-36-3    | F           | zero        | 0.0005            | D '93              | -                 | -              | -               | -           | -                | 0.01                                 | B2                   |
| Prometon                               | 1610-18-0    | -           | -           | -                 | F '88              | 0.2               | 0.2            | <i>0.05</i>     | 2           | 0.4              | -                                    | <i>N</i>             |
| Pronamide                              | 23950-58-5   | -           | -           | -                 | F '88              | 0.8               | 0.8            | <i>0.08</i>     | 3           | -                | <i>0.1</i>                           | <i>B2</i>            |
| Propachlor                             | 1918-16-7    | -           | -           | -                 | F '88              | 0.5               | 0.5            | <i>0.05</i>     | 2           | -                | 0.1                                  | <i>L</i>             |
| Propazine                              | 139-40-2     | -           | -           | -                 | F '88              | -                 | -              | <i>0.02</i>     | 0.7         | 0.01             | -                                    | <i>N</i>             |
| Propam                                 | 122-42-9     | -           | -           | -                 | F '88              | 5                 | 5              | 0.02            | 0.6         | 0.1              | -                                    | D                    |
| Pyrene (PAH)                           | 129-00-0     | -           | -           | -                 | -                  | -                 | -              | 0.03            | -           | -                | -                                    | D                    |
| RDX <sup>5</sup>                       | 121-82-4     | -           | -           | -                 | F '88              | 0.1               | 0.1            | 0.003           | 0.1         | 0.002            | 0.03                                 | C                    |
| Simazine                               | 122-34-9     | F           | 0.004       | 0.004             | F '88              | -                 | -              | <i>0.02</i>     | 0.7         | -                | -                                    | <i>N</i>             |
| Styrene                                | 100-42-5     | F           | 0.1         | 0.1               | F '87              | 20                | 2              | 0.2             | 7           | 0.1              | -                                    | C                    |
| 2,4,5-T (Trichlorophenoxy-acetic acid) | 93-76-5      | -           | -           | -                 | F '88              | 0.8               | 0.8            | 0.01            | 0.35        | 0.07             | -                                    | D                    |

<sup>1</sup> 1998 Final Rule for Disinfectants and Disinfection By-products: the total for five haloacetic acids is 0.06mg/L.

<sup>2</sup> The Health Advisory Document for nitrocellulose does not include HA values and describes this compound as relatively nontoxic.

<sup>3</sup> Perfluorooctanoic Acid. Provisional short-term value 0.0004mg/L.





<sup>4</sup> PerfluorooctaneSulfonate. Provisional short-term value 0.0002mg/L.

<sup>5</sup> RDX = hexahydro -1,3,5-trinitro-1,3,5-triazine.

# Drinking Water Standards and Health Advisories

Spring 2012

Page 7 of 12

| Chemicals  | CASRN Number | Standards   |             |                   | Status HA Document | Health Advisories |                |                 |             |                  |                                      | Cancer Descriptor |
|--|--------------|-------------|-------------|-------------------|--------------------|-------------------|----------------|-----------------|-------------|------------------|--------------------------------------|-------------------|
|  |              | Status Reg. | MCLG (mg/L) | MCL (mg/L)        |                    | 10-kg Child       |                |                 |             |                  |                                      |                   |
|  |              |             |             |                   |                    | One-day (mg/L)    | Ten-day (mg/L) | RfD (mg/kg/day) | DWEL (mg/L) | Life-time (mg/L) | mg/L at 10 <sup>-4</sup> Cancer Risk |                   |
| 2,3,7,8-TCDD (Dioxin)  | 1746-01-6    | F           | zero        | 3E-08             | F '87              | 1E-06             | 1E-07          | 1E-09           | 4E-08       | -                | 2E-08                                | B2                |
| Tebuthiuron  | 34014-18-1   | -           | -           | -                 | F '88              | 3                 | 3              | 0.07            | 2           | 0.5              | -                                    | D                 |
| Terbacil   | 5902-51-2    | -           | -           | -                 | F '88              | 0.3               | 0.3            | 0.01            | 0.4         | 0.09             | -                                    | E                 |
| Terbufos   | 13071-79-9   | -           | -           | -                 | F '88              | 0.005             | 0.005          | <b>0.00005</b>  | 0.002       | 0.0004           | -                                    | D                 |
| Tetrachloroethane (1,1,1,2-)   | 630-20-6     | -           | -           | -                 | F '89              | 2                 | 2              | 0.03            | 1           | 0.07             | 0.1                                  | C                 |
| Tetrachloroethane (1,1,2,2-)   | 79-34-5      | -           | -           | -                 | F '08              | 3                 | 3              | 0.01            | 0.4         | -                | 0.04                                 | L                 |
| Tetrachloroethylene <sup>1</sup>   | 127-18-4     | F           | zero        | 0.005             | F '87              | 2                 | 2              | 0.01            | 0.5         | 0.01             | -                                    | -                 |
| Tetrachloroterephthalic acid   | 236-79-0     | -           | -           | -                 | F '08              | 100               | 100            | -               | -           | -                | -                                    | I                 |
| Trichlorofluoromethane   | 75-69-4      | -           | -           | -                 | F '89              | 7                 | 7              | 0.3             | 10          | 2                | -                                    | D                 |
| Toluene  | 108-88-3     | F           | 1           | 1                 | D '93              | 20                | 2              | <b>0.08</b>     | 3           | -                | -                                    | <b>I</b>          |
| Toxaphene  | 8001-35-2    | F           | zero        | 0.003             | F '96              | 0.004             | 0.004          | 0.0004          | 0.01        | -                | 0.003                                | B2                |
| 2,4,5-TP (Silvex)  | 93-72-1      | F           | 0.05        | 0.05              | F '88              | 0.2               | 0.2            | 0.008           | 0.3         | 0.05             | -                                    | D                 |
| Trichloroacetic acid   | 76-03-9      | F           | 0.02        | 0.06 <sup>2</sup> | -                  | 3                 | 3              | 0.03            | 1           | 0.02             | -                                    | S                 |
| Trichlorobenzene (1,2,4-)  | 120-82-1     | F           | 0.07        | 0.07              | F '89              | 0.1               | 0.1            | <b>0.01</b>     | 0.35        | 0.07             | -                                    | D                 |
| Trichlorobenzene (1,3,5-)  | 108-70-3     | -           | -           | -                 | F '89              | 0.6               | 0.6            | 0.006           | 0.2         | 0.04             | -                                    | D                 |
| Trichloroethane (1,1,1-)   | 71-55-6      | F           | 0.2         | 0.2               | F '87              | 100               | 40             | <b>2</b>        | 70          | -                | -                                    | <b>I</b>          |
| Trichloroethane (1,1,2-)   | 79-00-5      | F           | 0.003       | 0.005             | F '89              | 0.6               | 0.4            | 0.004           | 0.1         | 0.003            | 0.06                                 | C                 |
| Trichloroethylene <sup>1</sup>  | 79-01-6      | F           | zero        | 0.005             | F '87              | -                 | -              | 0.007           | 0.2         | -                | 0.3                                  | B2                |
| Trichlorophenol (2,4,6-        | 88-06-2      | -           | -           | -                 | D '94              | 0.03              | 0.03           | 0.0003          | 0.01        | -                | 0.3                                  | B2                |
| Trichloropropane (1,2,3-)  | 96-18-4      | -           | -           | -                 | F '89              | 0.6               | 0.6            | <b>0.004</b>    | 0.1         | -                | -                                    | <b>L</b>          |
| Trifluralin  | 1582-09-8    | -           | -           | -                 | F '90              | 0.08              | 0.08           | <b>0.02</b>     | 0.7         | 0.01             | 0.4                                  | <b>C</b>          |
| Trimethylbenzene (1,2,4-)  | 95-63-6      | -           | -           | -                 | D '87              | -                 | -              | -               | -           | -                | -                                    | D                 |
| Trimethylbenzene (1,3,5-)  | 108-67-8     | -           | -           | -                 | D '87              | 10                | -              | -               | -           | -                | -                                    | D                 |
| Trinitroglycerol   | 55-63-0      | -           | -           | -                 | F '87              | 0.005             | 0.005          | -               | -           | 0.005            | 0.2                                  | -                 |
| Trinitrotoluene (2,4,6-)   | 118-96-7     | -           | -           | -                 | F '89              | 0.02              | 0.02           | 0.0005          | 0.02        | 0.002            | 0.1                                  | C                 |
| Vinyl chloride                | 75-01-4      | F           | zero        | 0.002             | F '87              | 3                 | 3              | <b>0.003</b>    | 0.1         | -                | <b>0.002</b>                         | <b>H</b>          |
| Xylenes                       | 1330-20-7    | F           | 10          | 10                | D '93              | 40                | 40             | <b>0.2</b>      | 7           | -                | -                                    | <b>I</b>          |

<sup>1</sup> Under review.

<sup>2</sup> 1998 Final Rule for Disinfectants and Disinfection By-products: The total for five haloacetic acids is 0.06 mg/L.

# Drinking Water Standards and Health Advisories

Spring 2012

Page 8 of 12

| Chemicals                        | CASRN Number | Standards      |                    |                  | Status<br>HA Document | Health Advisories |                   |                            |                |                     |  | Cancer<br>Descriptor |
|----------------------------------|--------------|----------------|--------------------|------------------|-----------------------|-------------------|-------------------|----------------------------|----------------|---------------------|--|----------------------|
|                                  |              | Status<br>Reg. | MCLG<br>(mg/L)     | MCL<br>(mg/L)    |                       | 10-kg Child       |                   | RfD<br>(mg/kg/day)         | DWEL<br>(mg/L) | Life-time<br>(mg/L) | mg/L at<br>10 <sup>-4</sup> Cancer<br>Risk |                      |
|                                  |              |                |                    |                  |                       | One-day<br>(mg/L) | Ten-day<br>(mg/L) |                            |                |                     |  |                      |
|                                  |              |                |                    |                  |                       |                   |                   |                            |                |                     |  |                      |
| INORGANICS                       |              |                |                    |                  |                       |                   |                   |                            |                |                     |  |                      |
| Ammonia                          | 7664-41-7    | -              | -                  | -                | D '92                 | -                 | -                 | -                          | -              | 30                  | -  | D                    |
| Antimony                         | 7440-36-0    | F              | 0.006              | 0.006            | F '92                 | 0.01              | 0.01              | 0.0004                     | 0.01           | 0.006               | -  | D                    |
| Arsenic                          | 7440-38-2    | F              | zero               | 0.01             | -                     | -                 | -                 | <b>0.0003</b>              | 0.01           | -                   | <b>0.002</b>                               | A                    |
| Asbestos (fibers/l >10Fm length) | 1332-21-4    | F              | 7 MFL <sup>1</sup> | 7 MFL            | -                     | -                 | -                 | -                          | -              | -                   | 700-MFL                                    | A <sup>2</sup>       |
| Barium                           | 7440-39-3    | F              | 2                  | 2                | D '93                 | 0.7               | 0.7               | <b>0.2</b>                 | 7              | -                   | -  | N                    |
| Beryllium                        | 7440-41-7    | F              | 0.004              | 0.004            | F '92                 | 30                | 30                | <b>0.002</b>               | 0.07           | -                   | -  | -                    |
| Boron                            | 7440-42-8    | -              | -                  | -                | F '08                 | 3                 | 3                 | <b>0.2</b>                 | 7              | 6                   | -  | I                    |
| Bromate                          | 7789-38-0    | F              | zero               | 0.01             | D '98                 | 0.2               | -                 | <b>0.004</b>               | 0.14           | -                   | 0.005                                      | B2                   |
| Cadmium                          | 7440-43-9    | F              | 0.005              | 0.005            | F '87                 | 0.04              | 0.04              | 0.0005                     | 0.02           | 0.005               | -  | D                    |
| Chloramine <sup>3</sup>          | 10599-90-3   | F              | 4 <sup>4</sup>     | 4 <sup>4</sup>   | D '95                 | -                 | -                 | 0.1                        | 3.5            | 3.0                 | -  | -                    |
| Chlorine                         | 7782-50-5    | F              | 4 <sup>4</sup>     | 4 <sup>4</sup>   | D '95                 | 3                 | 3                 | 0.1                        | 5              | 4                   | -  | D                    |
| Chlorine dioxide                 | 10049-04-4   | F              | 0.8 <sup>4</sup>   | 0.8 <sup>4</sup> | D '98                 | 0.8               | 0.8               | 0.03                       | 1              | 0.8                 | -  | D                    |
| Chlorite                         | 7758-19-2    | F              | 0.8                | 1                | D '98                 | 0.8               | 0.8               | 0.03                       | 1              | 0.8                 | -  | D                    |
| Chromium (total)                 | 7440-47-3    | F              | 0.1                | 0.1              | F '87                 | 1                 | 1                 | <b>0.003</b> <sup>5</sup>  | 0.1            | -                   | -  | D                    |
| Copper (at tap)                  | 7440-50-8    | F              | 1.3                | TT <sup>6</sup>  | D '98                 | -                 | -                 | -                          | -              | -                   | -  | D                    |
| Cyanide                          | 143-33-9     | F              | 0.2                | 0.2              | F '87                 | 0.2               | 0.2               | <b>0.0006</b> <sup>7</sup> | -              | -                   | -  | I                    |
| Fluoride                         | 7681-49-4    | F              | 4                  | 4                | -                     | - <sup>8</sup>    | -                 | <b>0.06</b> <sup>9</sup>   | -              | -                   | -  | -                    |
| Lead (at tap)                    | 7439-92-1    | F              | zero               | TT <sup>6</sup>  | -                     | -                 | -                 | -                          | -              | -                   | -  | B2                   |
| Manganese                        | 7439-96-5    | -              | -                  | -                | F '04                 | 1                 | 1                 | 0.14 <sup>10</sup>         | 1.6            | 0.3                 | -  | D                    |
| Mercury (inorganic)              | 7487-94-7    | F              | 0.002              | 0.002            | F '87                 | 0.002             | 0.002             | <b>0.0003</b>              | 0.01           | 0.002               | -  | D                    |
| Molybdenum                       | 7439-98-7    | -              | -                  | -                | D '93                 | 0.08              | 0.08              | 0.005                      | 0.2            | 0.04                | -  | D                    |
| Nickel                           | 7440-02-0    | F              | -                  | -                | F '95                 | 1                 | 1                 | 0.02                       | 0.7            | 0.1                 | -  | -                    |

<sup>1</sup> MFL = million fibers per liter.

<sup>2</sup> Carcinogenicity based on inhalation exposure.

<sup>3</sup> Monochloramine; measured as free chlorine.

<sup>4</sup> 1998 Final Rule for Disinfectants and Disinfection By-products: MRDLG=Maximum Residual Disinfection Level Goal; and MRDL=Maximum Residual Disinfection Level.

<sup>5</sup> IRIS value for chromium VI.

<sup>6</sup> Copper action level 1.3 mg/L; lead action level 0.015 mg/L.

<sup>7</sup> This RfD is for hydrogen cyanide.

<sup>8</sup> In case of overfeed of the fluoridation chemical see CDC Guidelines in Engineering and Administrative Recommendations on Water Fluoridation [www.cdc.gov/mmwr/preview/mmwrhtml/00039178.htm](http://www.cdc.gov/mmwr/preview/mmwrhtml/00039178.htm). Elevated F levels ≥ 10mg/L require action by the water system operator.

<sup>9</sup> Based on dental fluorosis in children, a cosmetic effect. MCLG based on skeletal fluorosis.

<sup>10</sup> Dietary manganese. The lifetime health advisory includes a 3 fold modifying factor to account for increased bioavailability from drinking water.



# Drinking Water Standards and Health Advisories

Spring 2012

Page 9 of 12

| Chemicals   | CASRN Number | Standards      |                |  | Status<br>HA Document | Health Advisories |                   |                     |                |                         |   | Cancer<br>Descriptor |
|---|--------------|----------------|----------------|--|-----------------------|-------------------|-------------------|---------------------|----------------|-------------------------|---|----------------------|
|   |              | Status<br>Reg. | MCLG<br>(mg/L) | MCL<br>(mg/L)                                |                       | 10-kg Child       |                   | RfD<br>(mg/kg/day)  | DWEL<br>(mg/L) | Life-<br>time<br>(mg/L) | mg/L at 10 <sup>-4</sup><br>Cancer Risk |                      |
|   |              |                |                |  |                       | One-day<br>(mg/L) | Ten-day<br>(mg/L) |                     |                |                         |   |                      |
| Nitrate (as N)  | 14797-55-8   | F              | 10             | 10   | D '93                 | 100               | 100               | 1.6                 | -              | -                       | -                                       | -                    |
| Nitrite (as N)  | 14797-65-0   | F              | 1              | 1  | D '93                 | 10                | 10                | 0.16                | -              | -                       | -                                       | -                    |
| Nitrate + Nitrite (both as N)                                       |              | F              | 10             | 10   | D '93                 | -                 | -                 | -                   | -              | -                       | -                                       | -                    |
| Perchlorate <sup>2</sup>  | 14797-73-0   | -              | -              | -  | I '08                 | -                 | -                 | 0.007               | 0.025          | 0.015                   | -                                       | L/N                  |
| Selenium  | 7782-49-2    | F              | 0.05           | 0.05   | -                     | -                 | -                 | 0.005               | 0.2            | 0.05                    | -                                       | D                    |
| Silver  | 7440-22-4    | -              | -              | -  | F '92                 | 0.2               | 0.2               | 0.005 <sup>3</sup>  | 0.2            | 0.1 <sup>3</sup>        | -                                       | D                    |
| Strontium   | 7440-24-6    | -              | -              | -  | D '93                 | 25                | 25                | <b>0.6</b>          | 20             | 4                       | -                                       | D                    |
| Thallium  | 7440-28-0    | F              | 0.0005         | 0.002  | F '92                 | 0.007             | 0.007             | -                   | -              | -                       | -                                       | <b>I</b>             |
| White phosphorous   | 7723-14-0    | -              | -              | -  | F '90                 | -                 | -                 | 0.00002             | 0.0005         | 0.0001                  | -                                       | D                    |
| Zinc  | 7440-66-6    | -              | -              | -  | D '93                 | 6                 | 6                 | 0.3                 | 10             | 2                       | -                                       | <b>I</b>             |
| <b>RADIONUCLIDES</b>  |              |                |                |  |                       |                   |                   |                     |                |                         |   |                      |
| Beta particle and photon activity (formerly man-made radionuclides) |              | F              | zero           | 4 mrem/yr                                    | -                     | -                 | -                 | -                   | -              | -                       | 4 mrem/yr                               | A                    |
| Gross alpha particle activity                                       |              | F              | zero           | 15 pCi/L                                     | -                     | -                 | -                 | -                   | -              | -                       | 15 pCi/L                                | A                    |
| Combined Radium 226 & 228   | 7440-14-4    | F              | zero           | 5 pCi/L                                      | -                     | -                 | -                 | -                   | -              | -                       | -                                       | A                    |
| Radon   | 10043-92-2   | P              | zero           | 300 pCi/L<br>AMCL <sup>4</sup><br>4000 pCi/L | -                     | -                 | -                 | -                   | -              | -                       | 150 pCi/L                               | A                    |
| Uranium   | 7440-61-1    | F              | zero           | 0.03   | -                     | -                 | -                 | 0.0006 <sup>5</sup> | 0.02           | -                       | -                                       | A                    |

<sup>1</sup> These values are calculated for a 4-kg infant and are protective for all age groups.

<sup>2</sup> Subchronic value for pregnant women.

<sup>3</sup> Based on a cosmetic effect.

<sup>4</sup> AMCL = Alternative Maximum Contaminant Level.

<sup>5</sup> Soluble uranium salts. Radionuclide Rule.

## ***Drinking Water Standards and Health Advisories***

Spring 2012

Page 10 of 12

### ***Secondary Drinking Water Regulations***

| <b>Chemicals</b>             | <b>CAS Number</b> | <b>Status</b> | <b>SDWR</b>              |
|------------------------------|-------------------|---------------|--------------------------|
| Aluminum                     | 7429-90-5         | F             | 0.05 to 0.2 mg/L         |
| Chloride                     | 7647-14-5         | F             | 250 mg/L                 |
| Color                        | NA                | F             | 15 color units           |
| Copper                       | 7440-50-8         | F             | 1.0 mg/L                 |
| Corrosivity                  | NA                | F             | non-corrosive            |
| Fluoride                     | 7681-49-4         | F             | 2.0 mg/L                 |
| Foaming agents               | NA                | F             | 0.5 mg/L                 |
| Iron                         | 7439-89-6         | F             | 0.3 mg/L                 |
| Manganese                    | 7439-96-5         | F             | 0.05 mg/L                |
| Odor                         | NA                | F             | 3 threshold odor numbers |
| pH                           | NA                | F             | 6.5 – 8.5                |
| Silver                       | 7440-22-4         | F             | 0.1 mg/L                 |
| Sulfate                      | 7757-82-6         | F             | 250 mg/L                 |
| Total dissolved solids (TDS) | NA                | F             | 500 mg/L                 |
| Zinc                         | 7440-66-6         | F             | 5 mg/L                   |

## ***Drinking Water Standards and Health Advisories***

Spring 2012

Page 11 of 12

### ***Microbiology***

|                                 | Status Reg.    | Status HA Document | MCLG | MCL | Treatment Technique   |
|---------------------------------|----------------|--------------------|------|-----|---|
| <i>Cryptosporidium</i>          | F              | F 01               | -    | TT  | Systems that filter must remove 99% of <i>Cryptosporidium</i>   |
| <i>Giardia lamblia</i>          | F              | F 98               | -    | TT  | 99.9% killed/inactivated  |
| <i>Legionella</i>               | F <sup>1</sup> | F 01               | zero | TT  | No limit; EPA believes that if <i>Giardia</i> and viruses are inactivated, <i>Legionella</i> will also be controlled  |
| Heterotrophic Plate Count (HPC) | F <sup>1</sup> | -                  | NA   | TT  | No more than 500 bacterial colonies per milliliter.   |
| Mycobacteria                    | -              | F 99               | -    | -   | -   |
| Total Coliforms                 | F              | -                  | zero | 5%  | No more than 5.0% samples total coliform-positive in a month. Every sample that has total coliforms must be analyzed for fecal coliforms; no fecal coliforms are allowed. |
| Turbidity                       | F              | -                  | NA   | TT  | At no time can turbidity go above 5 NTU (nephelometric turbidity units)   |
| Viruses                         | F <sup>1</sup> | -                  | zero | TT  | 99.99% killed/inactivated   |

<sup>1</sup> Regulated under the surface water treatment rule.

## ***Drinking Water Standards and Health Advisories***

Spring 2012

Page 12 of 12

### ***Drinking Water Advisory Table***

| <b>Chemicals</b>                          | <b>Status</b> | <b>Health-based Value</b>  | <b>Taste Threshold</b> | <b>Odor Threshold</b> |
|---|---------------|--|------------------------|-----------------------|
| <b>Ammonia</b>                            | <b>D '92</b>  | <b>Not Available</b>   | <b>30 mg/L</b>         |                       |
| <b>Methyl tertiary butyl ether (MtBE)</b> | <b>F '98</b>  | <b>Not Available</b>   | <b>40 µg/L</b>         | <b>20 µg/L</b>        |
| <b>Sodium</b>                             | <b>F '03</b>  | <b>20 mg/L (for individuals on a 500 mg/day restricted sodium diet).</b> | <b>30-60 mg/L</b>      |                       |
| <b>Sulfate</b>                            | <b>F '03</b>  | <b>500 mg/L</b>  | <b>250 mg/L</b>        |                       |

Taste Threshold: Concentration at which the majority of consumers do not notice an adverse taste in drinking water; it is recognized that some sensitive individuals may detect a chemical at levels below this threshold.

Odor Threshold: Concentration at which the majority of consumers do not notice an adverse odor in drinking water; it is recognized that some sensitive individuals may detect a chemical at levels below this threshold.